

Curve No. 1119

Size: 6JLO

RPM: 1760

EFFICIENCY CHANGE

STGS.	1	-6
"	3	-4
"	4	-2.5
"	5	-1.0

Perf. based on: Brz. Impellers & C.I. Vitriglass Enamelled Bowls.

Impeller= OPEN

K= 2.4 LBS./FT. 3.6 Kg./M.

K(Bal.)=

GOULDS PUMPS

VERTICAL PUMP DIVISION
CITY OF INDUSTRY, CALFORNIA

Characteristc based upon pumping clear, non-aerated water. Rating point only is guaranteed. Column losses not included.

PAGE 5C21

DATE July 22, 1977

SUPERSEDES New