



Curve No. E 3140

Model: 7CLC

RPM: 1770

EFFICIENCY CORRECTION

STGS. 1	-4.0
STGS. 2	-2.0
STGS. 3	-0.0

PERF BASED ON STD. MTL'S

Impeller= CLOSED

$N_s = 2183$

$K = 3.5 \text{ LBS/FT}$
 5.2 KG/M

$K (\text{Bal.}) =$



TURBINE DIVISION
LUBBOCK, TEXAS

Characteristics based upon pumping clear, non-aerated water. Rating point only is guaranteed. Column losses not included.

MODEL
7CLC

DATE
April, 1994
SUPERCEDES
April, 1993