

Curve No. 3005

Model: 8RJHO

RPM: 3500

EFFICIENCY CORRECTION

STGS. 1	-4.0
STGS. 2	-2.5
STGS. 3	-1.5
STGS. 4	-1.0

PERF BASED ON STD. MTL'S

Impeller= A8155

N_S= 2825

K= 5.3 LBS/FT
7.9 KG/M

K (Bal.)=

GOULDS PUMPS
TURBINE DIVISION
LUBBOCK, TEXAS

Characteristics based upon pumping clear, non-aerated water.
Rating point only is guaranteed. Column losses not included.

MODEL 8RJHO

DATE May 2, 1988

SUPERCEDES July 22, 1977

C8RJHO.1