

CHANGE EFFICIENCY AS FOLLOWS	NUMBER OF POINTS	FOR NUMBER OF STAGES
Lower	1	2
Lower	3	1

NOTE: ANY CHANGE IN EFFICIENCY CHANGES EITHER THE HEAD OR HORSE POWER IN PROPORTION

HYDRAULIC PERFORMANCE is contingent on the well furnishing the pump with the specified amount of clear, fresh, non-aerated water at a temperature of not to exceed 85 degrees Fahrenheit.

POMONA PUMPS

Fairbanks, Morse & Co.

Chicago 5, Illinois — Pomona California

LABORATORY PERFORMANCE
PER STAGE 20" M.C. DEEP WELL TURBINE
PUMP OPERATED AT 1160 R. P. M.
FIELD LOSS MUST BE DEDUCTED