


GOULDS PROPOSAL NO.	GOULDS S.O. NO.	INQUIRY NO.	CUSTOMER P.O. NO.	P.O. DATE	ITEM NO.	CUSTOMER
PROJECT	SERVICE		GPM CAPACITY	FT. TDH	% EFFICIENCY	RPM



<b>Curve No.</b>	
<b>E6616BBPC0</b>	
<b>Model</b>	<b>16BHC</b>
<b>RPM</b>	<b>1180</b>
<b>EFFICIENCY CORRECTION</b>	
1-STAGE	-2.0
2-STAGE	-1.0
3-STAGE	
4-STAGE	
<b>Impeller</b>	<b>ENCLOSED</b>
<b>Ns =</b>	<b>1963</b>
<b>K =</b>	<b>14.1 LBS/FT</b>
<b>K(Bal.)=</b>	<b>N/A</b>
Bowl O.D.	16.13"
Bowl Lateral	0.88"
Max. PSI	322
Min. Subm	24"
<b>GOULDS PUMPS</b>	
<b>TURBINE OPERATIONS</b>	
Lubbock, Texas	
BOWL PERFORMANCE CURVE BASED ON PUMPING CLEAR, NON-AERATED WATER. RATED POINT ONLY IS GUARANTEED. CURVES REPRESENT SINGLE STAGE PERFORMANCE BASED ON TEST OF MULTI-STAGE BOWL ASSEMBLY. EFFICIENCY CORRECTION IS REQUIRED FOR LESSER STAGES.	