


GOULDS PROPOSAL NO.	GOULDS S.O. NO.	INQUIRY NO.	CUSTOMER P.O. NO.	P.O. DATE	ITEM NO.	CUSTOMER
PROJECT	SERVICE		GPM CAPACITY	FT. TDH	% EFFICIENCY	RPM



<b>Curve No.</b> <b>E6620CFPF0</b>	
<b>Model</b>	<b>20CLC</b>
<b>RPM</b>	<b>1180</b>
<b>EFFICIENCY CORRECTION</b>	
1-STAGE	-1.5
2-STAGE	
3-STAGE	
Bal. Imps.	-2.0
<b>Impeller</b>	<b>ENCLOSED</b>
<b>Ns =</b>	<b>2258</b>
<b>K =</b>	<b>29.0 LBS/FT</b>
<b>K (Bal.)=</b>	<b>7.3 LBS/FT</b>
Bowl O.D.	20.5"
Bowl Lateral	
Max. PSI	250
Min. Subm	34"
<b>GOULDS PUMPS</b>	
<b>TURBINE OPERATIONS</b>	
Lubbock, Texas	
BOWL PERFORMANCE CURVE BASED ON PUMPING CLEAR, NON-AERATED WATER. RATED POINT ONLY IS GUARANTEED. CURVES REPRESENT SINGLE STAGE PERFORMANCE BASED ON TEST OF MULTI-STAGE BOWL ASSEMBLY. EFFICIENCY CORRECTION IS REQUIRED FOR LESSER STAGES.	