


GOULDS PROPOSAL NO.	GOULDS S.O. NO.	INQUIRY NO.	CUSTOMER P.O. NO.	P.O. DATE	ITEM NO.	CUSTOMER
PROJECT	SERVICE		GPM CAPACITY	FT. TDH	% EFFICIENCY	RPM



<b>Curve No.</b>	
<b>E6628TBPC0</b>	
<b>Model</b>	<b>28TLO</b>
<b>RPM</b>	<b>1180</b>
<b>EFFICIENCY CORRECTION</b>	
1-STAGE	-1.0
2-STAGE	
3-STAGE	
Bal. Imps.	
<b>Impeller</b>	<b>OPEN</b>
<b>Ns =</b>	<b>3976</b>
<b>K =</b>	<b>84.0 LBS/FT</b>
<b>K (Bal.)=</b>	<b>N/A</b>
Bowl O.D.	26.13"
Bowl Lateral	0.87"
Max. PSI	300
Min. Subm	51"
<b>GOULDS PUMPS</b>	
<b>TURBINE OPERATIONS</b>	
Lubbock, Texas	
BOWL PERFORMANCE CURVE BASED ON PUMPING CLEAR, NON-AERATED WATER. RATED POINT ONLY IS GUARANTEED. CURVES REPRESENT SINGLE STAGE PERFORMANCE BASED ON TEST OF MULTI-STAGE BOWL ASSEMBLY. EFFICIENCY CORRECTION IS REQUIRED FOR LESSER STAGES.	