


GOULDS PROPOSAL NO.	GOULDS S.O. NO.	INQUIRY NO.	CUSTOMER P.O. NO.	P.O. DATE	ITEM NO.	CUSTOMER
PROJECT	SERVICE		GPM CAPACITY	FT. TDH	% EFFICIENCY	RPM



<b>Curve No.</b>	
<b>E6206DFPC0</b>	
<b>Model</b>	<b>6DHLO</b>
<b>RPM</b>	<b>3450</b>
<b>EFFICIENCY CORRECTION</b>	
1-STAGE	-3.0
2-STAGE	-2.0
3-STAGE	-1.0
4-STAGE	0.0
<b>Impeller</b>	<b>OPEN</b>
<b>Ns =</b>	<b>4233</b>
<b>K =</b>	<b>5.6 LBS/FT</b>
<b>K(Bal.)=</b>	<b>N/A</b>
Bowl O.D.	5.44"
Bowl Lateral	0.44"
Max. PSI	200
Disch size	3", 4"
<b>GOULDS PUMPS</b>	
<b>TURBINE OPERATIONS</b>	
Lubbock, Texas	
BOWL PERFORMANCE CURVE BASED ON PUMPING CLEAR, NON-AERATED WATER. RATED POINT ONLY IS GUARANTEED. CURVES REPRESENT SINGLE STAGE PERFORMANCE BASED ON TEST OF MULTI-STAGE BOWL ASSEMBLY. EFFICIENCY CORRECTION IS REQUIRED FOR LESSER STAGES.	