Peerless Pump Company
Indianapolis, IN 46207-7025

VERTICAL TURBINE PUMPS
Model 8HDX- 1770 Rpm



EFFICIENCY ADJUSTMENT FOR STAGING	
STAGES	NUMBER OF POINTS
1	Lower 4
2	Lower 3
3	Lower 2
4	Lower 1

NOTE: ANY CHANGE IN EFFICIENCY AFFECTS EITHER THE HEAD OR HORSEPOWER CORRESPONDINGLY

HYDRAULIC PERFORMANCE WARRANTY	CURVE NO.	IMPELLER NO.	IMPELLER DIA.	TAKEN FROM
Guaranteed at designated point only, and contingent on:	1	4602048	5.58 x 6.97	63037
Proper flow to pump suction	2	4602048	4.56 x 5.75	63362
Proper submergence Fluid free of gas, air & abrasives	3			
Proper lateral setting of impeller	4			

Customer _____

Item _____

Peerless Ref. No: _____

Laboratory Performance — BOWL 4602047 D.I.E.

SIZE 8HDX — RPM 1770 — CURVE 4806407

PUMP DESCRIPTION: Driver _____; Head _____; Column _____

GUARANTEED BOWL ☐ FIELD ☐ PERFORMANCE: Capacity _____ gpm; Head _____ ft; Eff _____ %; BHP _____