

EFFICIENCY ADJUSTMENT FOR STAGING	
STAGES	NUMBER OF POINTS
1	Lower 6.5
2	Lower 2.5
3	Lower 1.5
4	Lower 0.5

NOTE: ANY CHANGE IN EFFICIENCY AFFECTS EITHER THE HEAD OR HORSEPOWER CORRESPONDINGLY

2 POLE 60 HERTZ PERFORMANCE

GUARANTEED PERFORMANCE

◯ Bowl

◯ Field

Capacity _____ gpm

Head _____ Feet

BHP _____

EFFICIENCY _____ %

DRIVER

_____

_____

HEAD

_____

COLUMN

_____

_____

_____

HYDRAULIC PERFORMANCE WARRANTY	CURVE NO.	IMPELLER NO.	IMPELLER DIA.	TAKEN FROM
Guaranteed at designated point only, and contingent on:	1	2616465	5-15/16	55539
Proper flow to pump suction	2	2616465	5-15/32 x 5-15/16	55634
Proper submergence Fluid free of gas, air & abrasives	3	2616465	5-1/4 x 5-11/16	55644
Proper lateral setting of impeller	4			

Customer _____

_____

Item _____

Peerless Ref. No:

Laboratory Performance		BOWL 2616457 CIE
SIZE 8LB	RPM 3460	CURVE 4806269